## 

OPERATING SPECIFICATIONS ARE: AXIMUM PRESSURE 10.5BAR (150PSIG) MAXIMUM TEMPERATURE 49°C (120°F)

THIS VESSEL IS ONLY APPROVED FOR WATER PRESSURE USE ALL OTHER USES OR SOLUTIONS TO BE USED MUST BE APPROVED BY MANUFACTURER

THIS VESSEL NOT TO BE USED FOR PNEUMATIC OR HYDRO-PNEUMATIC APPLICATIONS.


VESSEL MUST NOT BE EXPOSED TO TEMPERATURE BELOW -29°C (-20°F)

**F**4 N0915AW050

PRESSURE VESSEL

Wave Cyber

FLEXIBILITY IN PIPING OR FLEX CONNECTORS ARE RECOMMENDED VACUUM BREAKER



SPE 3072

WADE BY WAVE CYBER FOR EUROTROL SPA

- COMPLIES WITH ALL REQUIREMENTS OF P.E.D. 97/23/EC DIRECTIVE SUITABLE FOR DRINKING WATER FOLLOWING KTW RECOMMENDATIONS

IN WARNING

1) TANK IS RATED FOR AN INTERNAL NEGATIVE PRESSURE OF 5"HG VACUUM BELOM ATMOSTIC PRESSURE, AN ADEQUATE VACUUM BREAKER MUST BE INSTALLED BETWEEN THE TANK IN THE BELOW ATMOSPHERIC, IF NEGATIVE PRESSURE EXCEEDS 5" HG NEGATIVE PRESSURE EXCEEDS 5" HG NEGATIVE PRESSURE THE TANK INLET AND ANY VALVES. (REFER TO PICTURE)

2) SYSTEM CONNECTIONS TO THE TANK MUST ACCOMMODATE LONGITUDINAL EXPANSION BETWEEN SIDE, AND TOP AND BOTTOM OPENINGS. FLEXIBILITY IN PIPING OR FLEX CONNECTORS ARE RECOMMENDED.